



TEST REPORT

1. Applicant

Name : i-Tork Controls Co., Ltd.
Address : 12-13, Gilju-ro 411 Beon-gil, Wonmi-Gu, Bucheon Si, Gyeonggi-Do, Korea

2. Products

Name : Multi Turn Actuator
Model/Type : ITM0180
Manufacturer : i-Tork Controls Co., Ltd.

3. Test Standard/Method : IEC 60529:2001, KS C IEC 60529:2006

4. Test Results : IP68 (Refer to document)

5. Use of Report : For Quality Control

6. Date of Application : 2014. 05. 13.

7. Date of Issue : 2014. 05. 28.

Tested by

Approved by

KIM CHANG HO

Base Technology Center

Kang Jun Gu

Base Technology Center

The above test report is the accredited test results by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.

2014. 05. 28.



Korea Testing Laboratory

Accredited by KOLAS, Republic of KOREA



87, Digital-ro 26-gil, Guro-gu, Seoul, KOREA

<http://www.ktl.re.kr>

Tel. : +82-2-860-1531

Fax. : +82-2-860-1549

FP202-03-02



* 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.

TEST RESULTS

for Degree of protection provided by enclosures(IP Code)



1. Test Results

Code letters	IP	Test method and Record	Results
<p>1st Characteristic numerals</p> <p>Against ingress of solid foreign objects</p>	6	<p>1. CONDITIONS</p> <p>1.1 Talcum powder(mesh) : Wire diameter=50 μm, width between wires=75 μm</p> <p>1.2 Amount of talcum powder of the test chamber : 2kg/m³</p> <p>2. TEST</p> <p>2.1 Volume of the enclosures: about 10000 cm³</p> <p>2.2 Reduction air pressure : -2.0 kPa (-200 mmH₂O)</p> <p>2.3 Flow rate : 0.0 LPM</p> <p>2.4 Extraction rate per hour : 0 volumes/h</p> <p>2.5 Test duration : 8 hours</p>	Pass
<p>2nd Characteristic numerals</p> <p>Against ingress of water with harmful effects</p>	8	<p>1. CONDITIONS</p> <p>1.1 The lowest point of enclosure : 600 mm</p> <p>1.2 The highest point of enclosure : 350 mm</p> <p>1.3 Differential temperature of water and enclosure (less than 5K) : about 2.0 K</p> <p>1.4 Hydraulic test : 1.0 kg/cm² (about 10 m)</p> <p>2. TEST</p> <p>2.1 The duration of the test is : 100 hours</p>	Pass

2. Reference Data

- (1) Test conditions : 21.8 °C, 49 %RH, 86~106 kPa
- (2) Size : 617 mm×516 mm×H354 mm
- (3) Rating : AC 220~480 V, 50/60 Hz

FP202-04-01



* 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.