

Certificate of Compliance

No. 8117703405-100-03

Manufacturer Susin I-Tork India (P) Limited
43 A, Vadaku Thottam Pakuthi, Idikarai, Coimbatore – 641 022
Tamil Nadu, India

Product PL Series Linear Pneumatic Actuators

Type

- PLS Series Spring Return
- PLD Series Double Acting

Results The PL Series Linear Pneumatic Actuators are suitable for use in safety related systems in low demand mode of operation according to IEC 61508: 2010 up to SIL 2 @ HFT=0 & SIL 3 @ HFT=1.

For detailed results see
Technical Report No. 8117703405-100-01 R0
For summary of results refer to Annexure I of this certificate

The product should be designed properly in order to be implemented in a Safety Instrumented System of E/E/PE type as per requirements of safety manual.

This certificate remains valid until March, 2023 subject to satisfactory Surveillance Audit.

Surveillance Audit Due: March, 2021

Date: June 19, 2020

Ajinkya Patil

Ajinkya Patil
Asst. Manager – Product Certification



Mahesh Gaur

Mahesh Gaur
GM – Product Certification